

UK DECLARATION OF CONFORMITY

Manufacturer	CAMLOGIC S.R.L. Via dell'Industria 12-12/A, 42025 Cavriago (RE)
---------------------	--


We hereby declare as manufacturer that the products:

Product	Rotary point level switch	PFG09 series
Year of production	2023	Serial number *1

Complies with the Directives listed below:

Relevant statutory requirements	Relevant designated standards
S.I. 2016 No. 1101	BS EN 61010-1:2010+A1:2019
S.I. 2016 No. 1091	BS EN 61326-1:2013
S.I. 2012 No. 3032	-
Optional: S.I. 2016 No. 1107	BS EN IEC 60079-0:2018 BS EN 60079-31:2014 BS EN 60079-26:2015 BS EN 60079-31:2014

Additional information for equipment with ATEX approval:

EU-Type Examination Certificate No. Issued by	TÜV IT 13 ATEX 072 TÜV Italia S.r.l. (Notified body N.0948)
Protection type	 II 1/2 D Ex ta/tb IIIC T85°C IP65 Da/Db Ta= -20°C ÷ +70°C II 1/2 G Ex d IIB T6 Ga/Gb Ta= -20°C ÷ +70°C *2 II 2 G Ex d IIB T6 Gb Ta= -20°C ÷ +70°C
Quality assurance / Issued by	TÜV IT 17 ATEX 001 Q TÜV Italia S.r.l. (Notified body N.0948)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The manufacturer declares that the product complies with the requirements of the latest editions of the standards.
 The changes of the latest editions have been checked and do not affect the product.

All related supporting documentation is available at the Company.



Cavriago, 04.01.2023
 G. Guazzetti (CEO)

Validity: until cancelled by reissue

*1 Available on request from the Company

*2 Only for models / Solo per le versioni: **PFG09/Z, PFG09/Z/AT**